3. No library of those inspected had taken all the precautions mentioned for protection against polluted air and variation of temperature and humidity.

4. Recommended storage conditions are those in which daylight and polluted air are excluded and the temperature and humidity maintained at 65° to 75° F., and 45 to 55 per cent, respectively.

VII. ACKNOWLEDGMENT

The assistance of the staffs of the libraries participating in this survey is gratefully acknowledged.

WASHINGTON, June 25, 1931.

O