

G.

CLARENCE T. ADAMS
ERNEST H. ADAMS
EDWARD L. CROSBY
HARRY W. GLASER

HENRY ADAMS, INC.
CONSULTING ENGINEERS
1263-1269 CALVERT BUILDING
BALTIMORE, MD.

June 7, 1934.

Re: Hall of Records.

Mr. Laurence H. Fowler,
347 N. Charles St.,
Baltimore, Md.

Dear Sir:-

In connection with the plumbing installation we find that due to the finish of the various toilet rooms, the installation of Josam shock absorbers will prove unsightly. We therefore recommend that air chambers be installed in lieu of shock absorbers on all lines to flushometers and wherever else required by the specifications.

Yours very truly,

HENRY ADAMS, INC.

By

E. Adams

EHA

6/9/34 Copy To Consolidated

U.S. BOND

100% RAG U.S.A.