BALTIMORE, MD. VOL. I.

35 (60-61)

33

RUSSELL

6" W. PIPE

20" W. PIPE

W. OSTEND (STOCKHOLM)

BRISCOE ST.

ORR, EPPLEY & CO. - BUILDERS SUPPLIES

WARE HO. SASH, DOORS & BLIND.

MORGAN MILL WORKS WARE HO. COLUMNS & SASHES.

LUMBER STORAGE

LUMBER SHED

LUMBER PILES

SMALL LUMBER PILES

SHED (VACANT)

LUMBER RACK

NO WATCHMAN - POWER: STEAM - HEAT: STEAM - FUEL: COAL - LIGHTS: ELECTRIC & GAS - CASKS & PAILS DISTRIB'D.

BOX STORAGE

PRINTING 1st OFFICE & SHIPPING 1st PACKING & MFG 2nd LABORATORY 3rd

SAW & DOOR STORAGE

OFFICE

HARNESS RM.

STABLE

MAGAZINE

TIN CLAD DOORS ON ALL HATCHES. 31 FIRE PAILS DISTRIB'D.

SHED

A. C. MEYER & CO. PROPRS OF DR. JOHN W. BULL'S REMEDIES, THE CARROLLTON CHEM. CO'S PREPARATIONS & J. H. WINKELMANN & CO'S SPECIALTIES

WARNER

44

5

CHINA ST.

W. WEST

BUILDING B

BUILDING E

BUILDING F

BUILDING C

BUILDING D

LUMBER PILES

PACKING SUPPLIES, STAINS & HAMMER DEPT 2nd

RE-INFORCED CONCRETE FLRS. ROOF & TWO ROWS OF CENTRE COLUMNS - 12"&9" WALLS WITH 20" PIERS 1st 15" - 12" - 9" & 8" STY.

Fireproof Constr'n.

ART ROOM 1st FOYER DEPT 2nd PACKING DEPT 1st

UPRIGHT FLY FINISHING 2nd FINISHING 3rd

GRAND FLY FINISHING 3rd FINISHING 4th

POLISHING DEPT 5th

ATTENTION OFFICE 1st METAL LATH & CEMENT PARTITIONS. BUILT 1906 1 CHEM. EXTGR. 1st

VARNISHING POLISHING

IRON BRIDGE

LUMBER SHED

STORAGE Not Sprinklered

STORAGE Not Sprinklered.

Tenements

VACANT

DRY KILN

LUMBER PILES 15'

Dismtd. Locos No. TANK, CAPCY. 6000 GAL.

LUMBER PILES 15'

20,000 GAL. W.T. ON 25' TOWER

VENEERING DEPT

Not Sprinklered

VACANT

Old Dilapidated & VACANT.

Wm KNABE PIANO CO. - FACTORY

B & O R. R.

S. EUTAW

36

W. CROSS

S. FREMONT AV.

APPROACH

Wm KNABE PIANO CO.

2 NIGHT & 1 SUNDAY WATCHMAN, R.W.T.O'CLOCK, TELE. 17 STATIONS. HOURLY ROUNDS. - POWER: CRUDE OIL ENG., ELECTRIC TRANSMISSION, I.E.P. INDIVIDUAL ELECTRIC MOTORS DISTRIB'D. - HEAT: STEAM - FUEL: SHAVINGS & COAL; - LIGHTS: ELECTRIC I.E.P. - METAL SHAVING BLOWERS TO ALL MACHINES. - SHAVINGS BLOWN DIRECT TO BURS FROM CYCLONES. - MANUFACTURERS AUTOMATIC SPRINKLERS; WET SYSTEM, NUMBER OF HEADS NOT KNOWN, HEADS SPACED 8'-4.8" SUPERVISORY SERVICE, MASTER MECHANIC. PRIMARY SUPPLY: CITY WATER, 45 TO 55 LBS. PRESSURE, 12" CONNECTION & UNDERWRITERS F.P. 18'x10'x12' CAPCY. 1000 GAL. PER MINUTE. - SECONDARY SUPPLY: 20,000 GAL. TANK ON 95' IRON TOWER, TANK ABOUT 25' ABOVE HIGHEST SPRINKLER HEAD. ANNUNCIATOR IN PUMP NO., GONG IN B'S ROOM, TWO AUXILIARY STEAMER CONNECTIONS. - PERFORATED LIVE STEAM PIPE IN DRY KILN. - FIVE Y.P.'S & ONE INTERIOR HYD. WITH 1400' 2½" HOSE & 300' 1" HOSE. - FIVE CHEM. EXTGRS. - FIRE PAILS & HAND GRENADES DISTRIB'D.

THE PULLMAN CO. STORE R'M.

RE-INFORCED CONCRETE & STEEL VIADUCT

45

9

10

S. HOWARD

46

Scale of Feet.

50 40 30 20 10 0 50 100 150